

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7300-0694:201 Page 1 of 1

**CATEGORY:** Misc. Devices/Control Unit Accessories

**LISTEE:** Fire Control Instruments, \*16 Southwest Park, Westwood MA 02090  
Contact: Anthony J. Shalna (781) 471-3000 FAX (781) 471-3099

**DESIGN:** Model AMM-4S monitor module. Unit is designed to support 2-wire detectors and may support normally open contact initiating devices.

**RATING:** 17.6 - 28.2 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as control unit accessory for use with listee's separately listed compatible fire alarm control units.

\*Rev. 02-05-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**FEBRUARY 5, 2004**

*Listing Expires June 30, 2004*

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager